



CERTIFICAT DE CALITATE PRODUS FINIT
СЕРТИФИКАТ КАЧЕСТВА
№ 2264

COD: CC-PF-001
EDITIA: 1
REVIZIA: 0
DATA: 15.01.2020.

- 1 DATA: 11.12.2020
2 DENUMIRE PRODUS FINIT: Plasa din fibre de sticla: 125
3 DATA PRODUCERE: 24.11.2020
4 TERMEN PASTRARE: 2 ani din data producerii

No	Indicator	Un.m	Norma	Rez.testelor	ACTE normative
1	Numarul de fire la 10 cm (directia longitudinala)	10 cm	20-21	20	EAD 040016-00-0404:2016, Cl. 2.2.6
2	Numarul de fire la 10 cm (directia transversala)	10 cm	15-18	17	EAD 040016-00-0404:2016, Cl. 2.2.6
3	Latime	cm	99,5-101	99,9	EAD 040016-00-0404:2016, Cl. 2.2.5
4	Greutate la 1 unitate de suprafata	g/m ²	125-152	135,8	EAD 040016-00-0404:2016, Cl. 2.2.8
5	Pierderi la calcinare	%	≥ 11	12,4	EAD 040016-00-0404:2016, Cl. 2.2.2
6	Sarcina la rupere (directia longitudinala)	N/ 5 cm	≥ 1200	1 714	u\o 040016-00-0404:2016, Cl. 2.2.7
7	Sarcina la rupere (directia transversala)	N/5 cm	≥ 1200	1 552	u\o 040016-00-0404:2016, Cl. 2.2.7
8	Sarcina la rupere (directia longitudinala 28 zile)	N/50 mm	≥ 1 000	902	u\o 040016-00-0404:2016, Cl. 2.2.7
9	Sarcina la rupere (directia transversala 28 zile)	N/50 mm	≥ 1 000	764	u\o 040016-00-0404:2016, Cl. 2.2.7
10	Dimensiunea celulei in directie longitudinala	mm	≥ 3	5,0	EAD 040016-00-0404:2016, Cl. 2.2.4
11	Dimensiunea celulei in directie transversala	mm	≥ 3	5,45	EAD 040016-00-0404:2016, Cl. 2.2.4

Director de Producere _____

