



CERTIFICAT DE CALITATE PRODUS FINIT
СЕРТИФИКАТ КАЧЕСТВА
№ 2263

COD: CC-PF-001
EDITIA: 1
REVIZIA: 0
DATA: 15.01.2020.

- 1 DATA: 17.03.2021
2 DENUMIRE PRODUS FINIT: Plasa din fibre de sticla: 165
3 DATA PRODUCERE: 19.02.2021
4 TERMEN PASTRARE: 2 ani din data producerii

No	Indicator	Un.m	Norma	Rez.testelor	ACTE normative
1	Numarul de fire la 10 cm (directia longitudinala)	10 cm	38-42	40	EAD 040016-00-0404:2016, Cl. 2.2.6
2	Numarul de fire la 10 cm (directia transversala)	10 cm	15-19	17	EAD 040016-00-0404:2016, Cl. 2.2.6
3	Latime	cm	99,5-101	100	EAD 040016-00-0404:2016, Cl. 2.2.5
4	Greutate la 1 unitate de suprafata	g/m ²	155 - 175	164,9	EAD 040016-00-0404:2016, Cl. 2.2.8
5	Pierderi la calcinare	%	≥ 15	18,18	EAD 040016-00-0404:2016, Cl. 2.2.2
6	Sarcina la rupere (directia longitudinala)	N/ 5 cm	≥ 2 000	2 509	u\o 040016-00-0404:2016, Cl. 2.2.7
7	Sarcina la rupere (directia transversala)	N/5 cm	≥ 2 000	2 626	u\o 040016-00-0404:2016, Cl. 2.2.7
8	Sarcina la rupere (directia longitudinala 28 zile)	N/50 mm	≥ 1 000	1662	u\o 040016-00-0404:2016, Cl. 2.2.7
9	Sarcina la rupere (directia transversala 28 zile)	N/50 mm	≥ 1 000	1 667	u\o 040016-00-0404:2016, Cl. 2.2.7
10	Dimensiunea celulei in directie longitudinala	mm	≥ 3	5,0	EAD 040016-00-0404:2016, Cl. 2.2.4
11	Dimensiunea celulei in directie transversala	mm	≥ 3	5,0	EAD 040016-00-0404:2016, Cl. 2.2.4

Director de Producere _____

