



CERTIFICAT DE CALITATE PRODUS FINIT
СЕРТИФИКАТ КАЧЕСТВА
№ 1

COD: CC-PF-001

EDITIA: 1

REVIZIA: 0

DATA: 15.01.2020.

- 1 **DATA:** 01.09.2022.
2 **DENUMIRE PRODUS FINIT:** Plasa din fibre de sticla: 140 (40x40)
3 **DATA PRODUCERE:** 30.08.2022.
4 **TERMEN PASTRARE:** 2 ani din data producerii

No	Indicator	Un.m	Norma	Rez.testelor	ACTE normative
1	Numarul de fire la 10 cm (directia longitudinala)	f/10 cm	3	3	EAD 040016-00-0404:2016, Cl. 2.2.6
2	Numarul de fire la 10 cm (directia transversala)	f/10 cm	3	3	EAD 040016-00-0404:2016, Cl. 2.2.6
3	Greutate la 1 unitate de suprafata	g/m ²	135-145	141	EAD 040016-00-0404:2016, Cl. 2.2.8
4	Pierderi la calcinare	%	≥ 18	21,01	EAD 040016-00-0404:2016, Cl. 2.2.2
5	Sarcina la rupere (directia longitudinala)	N/5 cm	≥ 2000	2 190,0	u\o 040016-00-0404:2016, Cl. 2.2.7
6	Sarcina la rupere (directia transversala)	N/5 cm	≥ 2000	2 183,0	u\o 040016-00-0404:2016, Cl. 2.2.7
7	Dimensiunea celulei in directie longitudinala	mm	≥ 40/40	42,00	EAD 040016-00-0404:2016, Cl. 2.2.4
8	Dimensiunea celulei in directie transversala	mm	≥ 40/40	41,60	EAD 040016-00-0404:2016, Cl. 2.2.4

Director de Producere

